

- NOTES:
1. EVERY MODULE'S METALLIC FRAME MUST BE EARTHED BY CONNECTING THE FRAME TO THE METALLIC SUPPORTING STRUCTURE USING A 4mm² Cu/PVC/PVC PE CABLE.
 2. EVERY METALLIC SUPPORTING STRUCTURE MUST BE EARTHED USING A 16mm² Cu/PVC/PVC PE CABLE.
 3. EVERY PANELBOARD'S METALLIC ENCLOSURE AND METALLIC BACKSHEET MUST BE EARTHED USING A 4mm² Cu/PVC/PVC PE CABLE.
 4. ALL NEW EARTHING POINTS TO BE CONNECTED TO A NEW EARTHING SYSTEM DEDICATED FOR THE SOLAR PV SYSTEM.
 5. ALL PV CABLES SIZES TO BE 1C 4mm². CABLES TO BE KBE SOLAR PVI-F DC CABLE (OR EQUIVALENT). TDV CERTIFIED (TDV 2 PIG 1189/08.07), CU TINNED CLASS 5 CONDUCTOR (ACC. TO IEC 60228), CROSSLINKED SPECIAL POLYOLEFIN, HALOGEN FREE, OZONE RESISTANT, WEATHER & UV-RESISTANT INSULATION & JACKET MATERIAL, 1800VDC MAXIMUM OPEN CIRCUIT VOLTAGE RATING (CONDUCTOR-CONDUCTOR, NON EARTHED SYSTEM), FLAME RETARDANT ACC. TO IEC 60332-1.
 6. ALL PV CABLES SIZES TO BE 2x 1C 4mm². CABLES TO BE KBE SOLAR PVI-F DC CABLE (OR EQUIVALENT). TDV CERTIFIED (TDV 2 PIG 1189/08.07), CU TINNED CLASS 5 CONDUCTOR (ACC. TO IEC 60228), CROSSLINKED SPECIAL POLYOLEFIN, HALOGEN FREE, OZONE RESISTANT, WEATHER & UV-RESISTANT INSULATION & JACKET MATERIAL, 1800VDC MAXIMUM OPEN CIRCUIT VOLTAGE RATING (CONDUCTOR-CONDUCTOR, NON EARTHED SYSTEM), FLAME RETARDANT ACC. TO IEC 60332-1.
 7. ALL DC POWER CABLES FROM THE SOLAR CHARGE CONTROLLERS TO THE BATTERY BANK MUST BE 1C 25mm² UNARMORED Cu/PVC/PVC.
 8. ALL DC POWER CABLES FROM THE BATTERY BANK TO THE INVERTER/CHARGER MUST BE 2x 1C 25 mm² UNARMORED Cu/PVC/PVC. THE BATTERIES POSITIVE AND NEGATIVE BUSBARS SHALL BE WELL SEPARATED AND SECURED FOR SAFETY PURPOSES.
 9. ALL AC POWER CABLES TO/FROM THE OFF-GRID INVERTER MUST BE 2C 16mm² UNARMORED Cu/PVC/PVC, 0.6/1KV AND THE CORRESPONDING PE CABLES MUST BE 1C 16mm² UNARMORED Cu/PVC/PVC 0.5KV YELLOW/GREEN. ALL TO BE CONFORMING TO IEC 60502-1.
 10. ALL INVERTERS CABLE GLANDS OPENINGS MUST BE TIGHTLY SEALED USING THE SUPPLIED INVERTER MATERIAL TO ENSURE AN IP65 PROTECTION LEVEL.
 11. A POWER METER SHALL BE INSTALLED ON THE AC OUTPUT SIDE AFTER THE MTS TO DISPLAY AT LEAST THE VOLTAGE AND CURRENT READINGS.
 12. A PHASE FAILURE/OVER UNDER VOLTAGE PROTECTION RELAY WITH A NORMALLY OPEN CONTACTOR SHALL BE INSTALLED ON THE AC INPUT SIDE OF THE INVERTER TO PROTECT THE SYSTEM.


LEGEND:

SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION
	MONOCRYSTALLINE PV MODULE: RATED POWER: 410Wp Vmp: 41.28V, Imp: 9.78A DIMENSIONS(L/W/D): 2015x996x40mm		SOLAR INVERTER: HYBRID INVERTER - 150VA
	DOUBLE POLE DC FUSE WITH FUSE HOLDER: X REFERS TO THE VOLTAGE RATING (V). Y REFERS TO THE CURRENT RATING (A).		SOLAR CHARGE CONTROLLER 250V DC / 85A DC
	DOUBLE POLE DC DISCONNECTING SWITCH: X REFERS TO THE CURRENT RATING (A).		DOUBLE POLE AC THERMAL-MAGNETIC MINATURE CIRCUIT BREAKER: X REFERS TO THE TRIP CURRENT RATING (A).
	DOUBLE POLE DC SURGE ARRESTER: X REFERS TO THE SURGE ARRESTER TYPE (CLASS). Y REFERS TO THE NOMINAL DISCHARGE CURRENT RATING In (kA).		DOUBLE POLE AC THERMAL-MAGNETIC MINATURE CIRCUIT BREAKER WITH A CLASS AC RESIDUAL CURRENT PROTECTION: X REFERS TO THE TRIP CURRENT RATING (A). Y REFERS TO THE EARTH LEAKAGE PROTECTION SENSITIVITY (mA).
	BATTERY BANK: NUMBER OF BATTERIES IN SERIES: 24 NUMBER OF BATTERIES IN PARALLEL: 1 BATTERY BANK VOLTAGE: 48V		DOUBLE POLE AC SURGE ARRESTER: X REFERS TO THE SURGE ARRESTER TYPE (CLASS). Y REFERS TO THE NORMAL DISCHARGE CURRENT RATING In (kA).
			DOUBLE POLE DC CIRCUIT BREAKER: X REFERS TO THE TRIP CURRENT RATING (A).

REVISIONS:

REVISION NO.	DESCRIPTION	DATE
0	ISSUED FOR EXECUTION	03-04-23

CONSULTANT:



LCEC Engineering Office, 2nd floor Floor,
Level 5 Bldg, President Elias Hraoui Avenue,
Beirut, Lebanon
Email: energy@lcec.org.lb
Website: www.lcec.org.lb

CLIENT:

GIZ

PROJECT DESCRIPTION:

ROOF PV SYSTEM
KFARAAKKA – KOURA

DRAWING TITLE:

SLD

PROJECT PHASE:	DRAWING SCALE:	DRAWING DISCIPLINE:
EXECUTION	NTS	ELECTRICAL